

Table 2. Results of Cr6 Monitoring and RAAs⁽²⁾

**Coachella Valley Water District - Quarterly Cr6 Monitoring for CVWD Wells
Cove Public Water System (CA3310001)**

CVWD Well Site No.	2015 Quarter 1			2015 Quarter 2			2015 Quarter 3			2015 Quarter 4			2016 Quarter 1			2016 Quarter 2			2016 Quarter 3			2016 Quarter 4			2017 Quarter 1								
	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²						
4509-1	Not Applicable (N/A)																								1/11/2017	12 ⁽³⁾	12						
4510-1	1/1/2015	12	12	6/30/2015	12	12	9/24/2015	12	12	12/16/2015	12	12	1/26/2016	13	12	4/6/2016	12	12	7/20/2016	12	12	10/12/2016	12	12	1/13/2017	13	12						
4610-1	1/1/2015	14	14	6/16/2015	14	14	9/23/2015	14	14	12/16/2015	14	14	1/27/2016	15	14	4/14/2016	15	15	7/20/2016	15	15	10/11/2016	15	15	1/12/2017	15	15						
4628-2	1/1/2015	14	14	6/18/2015	14	14	9/24/2015	14	14	12/16/2015	13	14	1/26/2016	14	14	4/12/2016	14	14	7/21/2016	14	14	10/12/2016	14	14	1/19/2017	14	14						
4720-1	1/1/2015	16	16	6/16/2015	16	16	9/23/2015	16	16	12/16/2015	16	16	1/26/2016	17	16	4/6/2016	17	17	7/19/2016	17	17	10/11/2016	17	17	1/11/2017	17	17						
4721-1	1/1/2015	16	16	6/17/2015	17	17	9/24/2015	16	16	12/16/2015	16	16	1/27/2016	18	17	4/12/2016	17	17	7/20/2016	17	17	10/12/2016	18	18	1/12/2017	18	18						
4722-1	1/1/2015	14	14	6/16/2015	14	14	9/23/2015	14	14	12/16/2015	13	14	1/27/2016	14	14	4/6/2016	14	14	7/21/2016	14	14	10/11/2016	14	14	OFFLINE	-	14						
5632-2	Offline for Repair	-	-	6/17/2015	18	18	9/24/2015	17	18	12/16/2015	17	17	1/27/2016	18	18	4/12/2016	18	18	7/21/2016	18	18	10/11/2016	17	18	OFFLINE	-	18						
5657-2	New Well - Not in Service	-	-	6/16/2015	16	16	9/23/2015	16	16	12/16/2015	16	16	1/27/2016	17	16	4/6/2016	16	16	7/20/2016	16	16	10/11/2016	16	16	1/11/2017	16	16						
5664-1	1/1/2015	12	12	6/16/2015	11	12	9/23/2015	11	11	12/16/2015	11	11	1/26/2016	12	11	4/6/2016	12	12	7/20/2016	13	12	10/12/2016	12	12	1/12/2017	12	12						
5676-2	1/1/2015	12	12	6/16/2015	12	12	9/23/2015	12	12	12/16/2015	12	12	1/26/2016	12	12	4/6/2016	12	12	7/21/2016	12	12	10/11/2016	12	12	1/11/2017	12	12						
5677-1	1/1/2015	11	11	6/17/2015	10	11	9/24/2015	11	11	12/16/2015	11	11	1/27/2016	11	11	4/6/2016	11	11	7/22/2016	11	11	10/12/2016	10	11	1/13/2017	11	11						
5678-1	1/1/2015	14	14	6/16/2015	15	15	9/23/2015	16	15	12/16/2015	15	15	1/26/2016	16	16	4/12/2016	16	16	7/22/2016	16	16	10/12/2016	16	16	1/12/2017	16	16						
5679-1	1/1/2015	16	16	6/16/2015	16	16	9/23/2015	17	16	12/16/2015	16	16	1/26/2016	17	17	4/14/2016	17	17	7/22/2016	17	17	10/12/2016	17	17	1/13/2017	17	17						
5711-2	1/1/2015	11	11	6/16/2015	12	12	9/23/2015	12	12	12/16/2015	11	12	1/26/2016	12	12	4/12/2016	12	12	7/22/2016	12	12	10/12/2016	12	12	1/19/2017	12	12						
5717-1	1/1/2015	14	14	6/16/2015	14	14	9/23/2015	15	14	12/16/2015	14	14	1/26/2016	15	15	4/14/2016	15	15	7/20/2016	15	15	10/11/2016	15	15	1/12/2017	15	15						
5718-1	1/1/2015	16	16	6/17/2015	16	16	9/24/2015	16	16	12/16/2015	16	16	1/26/2016	17	16	4/14/2016	15	16	7/22/2016	15	16	10/12/2016	16	16	1/11/2017	16	16						
5719-1	1/1/2015	20	20	6/17/2015	20	20	9/23/2015	20	20	12/16/2015	20	20	1/26/2016	21	20	4/6/2016	20	20	7/22/2016	20	20	10/11/2016	19	20	1/13/2017	20	20						
5720-1	1/1/2015	15	15	6/17/2015	15	15	9/24/2015	15	15	12/16/2015	15	15	1/27/2016	16	15	4/12/2016	16	16	7/12/2016	16	16	10/12/2016	16	16	1/12/2017	16	16						
5725-1	Not Applicable (N/A)																								1/13/2017	11 ⁽⁴⁾	11						
5727-1	Not Applicable (N/A)																								1/19/2017	11 ⁽⁴⁾	11						
6701-1	1/1/2015	14	14	6/16/2015	14	14	9/23/2015	14	14	OFFLINE	-	14	OFFLINE	-	14	OFFLINE	-	14	8/4 & 9/13/2016	(6.7 & 14)	10	10/12/2016	14	12	1/11/2017	14	13						
6723-1	1/1/2015	11	11	6/17/2015	11	11	9/24/2015	11	11	12/16/2015	10	11	1/27/2016	11	11	4/12/2016	11	11	7/22/2016	11	11	10/12/2016	11	11	1/11/2017	11	11						
6724-1	1/1/2015	14	14	6/16/2015	13	14	9/23/2015	13	13	OFFLINE	-	13	OFFLINE	-	13	OFFLINE	-	13	OFFLINE	-	-	OFFLINE	-	-	OFFLINE	-	-						
6725-1	1/1/2015	13	13	6/17/2015	13	13	9/24/2015	12	13	12/16/2015	12	13	1/27/2016	13	13	4/12/2016	13	13	7/12/2016	14	13	10/12/2016	13	13	1/13/2017	13	13						
6726-1	1/1/2015	14	14	6/16/2015	14	14	9/23/2015	14	14	12/16/2015	14	14	1/26/2016	14	14	4/6/2016	14	14	7/20/2016	14	14	10/11/2016	14	14	1/12/2017	15	14						
6734-1	1/1/2015	15	15	6/16/2015	15	15	9/23/2015	15	15	12/16/2015	15	15	1/26/2016	16	15	4/6/2016	15	15	7/20/2016	13	15	10/12/2016	14	15	1/11/2017	13	14						
6805-1	1/1/2015	22	22	Standby Status																								11/30 & 12/7/2016	(7.3 & 8.1)	7.7	1/12/2017	15	11
6808-1	1/1/2015	20	20	6/16/2015	20	20	9/23/2015	20	20	12/16/2015	20	20	1/27/2016	20	20	6/2/2016	20	20	7/20/2016	19	20	10/12/2016	20	20	1/11/2017	23	21						

Notes:
 (1) Parts per Billion
 (2) Running Annual Average
 (3) Well previously on triennial monitoring schedule due to Cr6 result ≤ 10 ppb (9.8 ppb on 6/25/2014)
 (4) Well previously on triennial monitoring schedule due to Cr6 result ≤ 10 ppb (10 ppb on 6/25/2014)

Table 2. Results of Cr6 Monitoring and RAAs⁽²⁾

**Coachella Valley Water District - Quarterly Cr6 Monitoring for CVWD Wells
Improvement District No. 8 Public Water System (CA3310048)**

CVWD Well Site No.	2015 Quarter 1			2015 Quarter 2			2015 Quarter 3			2015 Quarter 4			2016 Quarter 1			2016 Quarter 2			2016 Quarter 3			2016 Quarter 4			2017 Quarter 1		
	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²	Sample Date	Result ppb ¹	RAA ²
3405-1	1/1/2015	13	13	6/17/2015	13	13	9/24/2015	14	13	12/16/2015	13	13	1/27/2016	13	13	4/6/2016	13	13	7/20/2016	12	13	10/11/2016	11	12	1/11/2017	12	12
3408-1	1/1/2015	19	19	6/16/2015	20	20	9/23/2015	20	20	12/16/2015	19	20	1/26/2016	20	20	4/12/2016	20	20	7/12/2016	20	20	10/12/2016	20	20	1/13/2017	20	20
3409-2	1/1/2015	22	22	<i>Standby Status</i>																							
3410-1	1/1/2015	14	14	6/16/2015	14	14	9/23/2015	14	14	12/16/2015	14	14	1/26/2016	15	14	4/12/2016	15	15	7/19/2016	16	15	10/11/2016	15	15	1/12/2017	16	16

Notes:
 (1) Parts per Billion
 (2) Running Annual Average