

1. Discharger shall maintain a copy of this permit at the place of business. This permit shall be surrendered to a District representative upon request. District will review the provisions of this permit at its discretion. The provisions may be revised by written notification mailed to the Discharger's address indicated on this permit. District reserves the right to revoke or suspend this permit at any time without notice.
2. Discharger shall comply with the District's Regulations Governing Sanitation Service and all applicable Federal and State discharge regulations. Slug discharges and discharges of chemical additives to the sewer, except as authorized by this discharge permit, are prohibited.
3. Discharger shall notify the District prior to any changes in its process or treatment unit that may affect the waste being discharged to the sewer. Discharger shall allow District staff to enter upon the premises containing the Cooling Tower(s) to inspect, sample, monitor or measure the Cooling Tower(s) and related facilities and the discharge from these facilities and shall make provision for access by District staff through locked gates or facilities. Discharger shall furnish to the District any and all documents reasonably requested by the District related to the Cooling Tower(s). Discharger shall reimburse the District within thirty (30) days of receiving an invoice from the District for any monitoring of the Cooling Tower(s) discharge performed by District staff to determine compliance with the District's Regulations Governing Sanitation Service.
4. Discharger shall develop and observe Best Management Practices so that the Cooling Tower(s) and related facilities are operated and maintained in a manner that ensures the discharge complies with Part 9 of the District's Regulations Governing Sanitation Service at all times.
5. Discharger shall install a water-measuring device which is capable of measuring and registering the accumulated amount of water provided to the Cooling Tower(s).
 - a. Any discharger using an existing District domestic water service providing water for Cooling Tower(s) and non-Cooling Tower(s) uses shall install a water-measuring device which is capable of measuring and registering the accumulated amount of water provided to the Cooling Tower(s).
 - b. Any Discharger installing new Cooling Tower(s) shall be required to install a dedicated service connection and water-measuring device.
6. Discharger shall install a district approved discharge sampling port on the Cooling Tower(s) discharge prior to entering the sewer.
7. Discharger shall have a representative sample of the discharge collected from the Cooling Towers discharge sampling port and analyzed for total dissolved solids semi-annually using a laboratory holding a valid certification or accreditation as required by CA Water Code Section 13176, for the requested analysis. A copy of the analytical result report for any and all monitoring performed on samples collected from the Cooling Tower(s) discharge sampling port during the previous six (6) months shall be reported to the District on January 15 and July 15 of each year.
8. Discharger shall record totalizer reads from all water-measuring devices installed in accordance with this permit on a monthly frequency and report to the District on a semi-annual basis the total accumulated amount of measured water for each device for each of the previous six (6) months on January 15 and July 15 of each year.